

STORMWATER MANAGEMENT

205 Attachment 3

Borough of Stockertown

Appendix D

Recommendation Chart for Infiltration Stormwater Management BMPs in Carbonate Bedrock*																													
FACTOR/SITE RISK	Geology Type	Carbonate Bedrock																											
	Effective Soil Thickness	Less than 2 feet	2 feet to 4 feet									Over 4 feet to 8 feet									Over 8 feet								
	Special Geologic Features**	Low/Med/High Buffer	Low Buffer			Medium Buffer			High Buffer			Low Buffer			Medium Buffer			High Buffer			Low Buffer			Medium Buffer			High Buffer		
SITE INVESTIGATION RECOMMENDED	(Unacceptable)	Preliminary			Preliminary			Preliminary			Preliminary			Preliminary			Preliminary			Preliminary			Preliminary			Preliminary			
FACTOR/DESIGN	Infiltration Loading Rates (% increase)***	(Unacceptable)	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%	0-100%	100-300%	300-500%
PROGRAM SUMMARY GUIDANCE****					1	1					1	2								1	2					1			

 Recommended  Not Recommended

NOTES:

* Source: Developed by Cahill Associates based on information in "Technical Best Management Practice Manual and Infiltration Feasibility Report," November 2002 and input from the LVPC, 2003.

** Special Geologic Feature Buffer widths are as follows:

Low Buffer is less than 50 feet.

Medium Buffer is 50 feet to 100 feet.

High Buffer is greater than 100 feet.

*** Rates greater than 500% not recommended.

**** Assumes adequately permeable soils and lack of natural constraints as required for all infiltration systems.

1 Infiltration systems may be allowed at the determination of the Engineer and/or Geologist, provided that a Detailed Site investigation is undertaken which confirms nature of rock, location of Special Geologic Features, and adequacy of the buffer between the SGF and the proposed stormwater system(s).

2 In these Special Geologic Features: Low Buffer situations, infiltration systems may be allowed at the determination of the Engineer and/or Geologist, provided that a Detailed Site Investigation is undertaken and a twenty-five-foot buffer from SGFs is maintained.